



- NOTES:
1. CONTROL PANEL WITH MEMA 1 ENCLOSURE SHALL BE INSTALLED WHERE SHOWN
  2. STEEL BASIN COVER SHALL BE A GRATING WITH OPENINGS AS REQUIRED FOR DISCHARGE PIPING, INLET PIPING (SAME AS FOR EXISTING SUMP PIT) AND CONTROLS
  3. EACH PUMP SHALL BE AS FOLLOWS: 100 GPM, 30 FT HD, 1750 RPM, 1 1/2 HP, 460 VOLTS, 3 PH, 60 HZ., FEDERAL PUMP CORP. MODEL YSS-2150-1 1/2 -4.

